

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52410

1. OWNER Allied Washoe ADDRESS AT WELL LOCATION 2500 EAST FOURTH ST  
 MAILING ADDRESS P.O. Box 6930 RENO NV  
RENO, NV 89513

2. LOCATION NE 1/4 NW 1/4 Sec. 7 T. 19 N. S. R. 20 E. Washoe County  
 PERMIT NO. 08-293-04 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND, COBBLES BRN		0	5	5
COARSE SAND COBBLES BRN		5	20	15
COBBLES FINE SAND BRN		20	30	10
COBBLES FINE SAND BRN/GRAY		30	50	20
SAND SMALL COBBLES GRAY	49	50	60	10
SAND W/ FINE SMALL COBBLES GRAY		60	72	12
<i>Plugged by log 122440</i>				

8. WELL CONSTRUCTION  
 Depth Drilled 72 Feet Depth Cased 70 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 5 1/2 Inches To 0 Feet 72 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"		SCH 40	0	65

Perforations:  
 Type perforation SLOT  
 Size perforation .020  
 From 65 feet to 50 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 56  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 61 feet to 72 feet

9. WATER LEVEL  
 Static water level 49 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 2-25-2006, 19\_\_\_\_\_  
 Date completed 2-25-2009, 19\_\_\_\_\_  
 7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Cascade Drilling, Inc Contractor  
 Address 3632 Omeo circle Contractor  
Rancho Cordova, CA 95742  
 Nevada contractor's license number 023-51207  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 2234  
 Division of Water Resources, the on-site driller  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 3-20-06