

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54212

1. OWNER MS. KELLEY ADDRESS AT WELL LOCATION 1335 E. JACOBSEN LANE GARDNERVILLE, NV
 MAILING ADDRESS GARDNERVILLE, NV
 2. LOCATION SW 1/4 NE 1/4 Sec 5 T 12 N 21 E DOUGLAS County
 PERMIT NO. 1221-05-001-040 Parcel No. FISH SPRINGS Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY w/COBBLES		0	8	8
CEMENTED SAND + GRAVEL		8	18	10
SANDY CLAY w/COBBLES		18	32	14
CEMENTED SAND + GRAVEL		32	55	23
SAND + GRAVEL		55	63	8
CEMENTED SAND + GRAVEL		63	94	31
GRAVEL + COBBLES	✓	94	117	23
SANDY CLAY w/GRAVEL		117	139	22
GRAVEL	✓	139	168	29
SANDY CLAY w/GRAVEL		168	220	52

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 5/8 Inches 0 Feet 50 Feet
9 7/8 Inches 50 Feet 220 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.5</u>	<u>.188</u>	<u>+1</u>	<u>220</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 1/16 x 3
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 220 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 1/26, 2006
 Date completed 3/22, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>AIR</u>	<u>30+</u>	<u>-</u>	<u>16</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name DESERT DRILLING CORPORATION Contractor
 Address 811 SPRING VALLEY RD. GARDNERVILLE, NV 89410 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 60503
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2282
 Signed Pat J. [Signature]
 By driller performing actual drilling on site or contractor
 Date 3/22/06