

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 99361  
 Permit No. \_\_\_\_\_  
 Basin 162

PRINT OR TYPE ONLY  
**DO NOT WRITE ON BACK**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29898

1. OWNER PAUL CYBORSKI ADDRESS AT WELL LOCATION 600 W GARDEN LN  
 MAILING ADDRESS 600 W GARDEN LN  
PAHRUMP, NV

2. LOCATION NE 1/4 SW 1/4-Sec. 28 T 20S N/S R 53E E NYE County  
 PERMIT NO. 39-083-08 Parcel No. CALVADA VALLEY UNIT 8B Subdivision Name

3. WORK PERFORMED  
 New-Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SILT		0	5	5
CLAY		5	15	10
CALICHE		15	35	20
CLAY		35	70	35
CALICHE	WB	70	81	11
CLAY		81	120	39
CALICHE	WB	120	135	15
CLAY		135	160	25
CALICHE	WB	160	168	8
CLAY		168	195	27
CALICHE		195	220	25

DCNR/DWR  
 RECEIVED  
 APR 14 2006  
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)  

Inches	From	To
<u>10</u>	<u>0</u>	<u>220</u>
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>3.63</u>	<u>.250</u>	<u>0</u>	<u>220</u>
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

Perforations:  
 Type perforation SAWCUT  
 Size perforation 1/8 X 3

From <u>120</u>	feet to <u>140</u>	feet
From <u>160</u>	feet to <u>180</u>	feet
From <u>200</u>	feet to <u>220</u>	feet
From _____	feet to _____	feet
From _____	feet to _____	feet

Surface Seal:  Yes  No  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 220 feet

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC.  
 Contractor

Date started 4/8/2006, 19  
 Date completed 4/8/2006, 19

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

Address 1220 E MANSE RD Contractor  
PAHRUMP, NV, 89048  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426  
 Signed [Signature]  
 By driller performing actual drilling on-site or contractor  
 Date 4/11/2006