

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57387

1. OWNER Gerald Hagemeyer ADDRESS AT WELL LOCATION 2975 Hawk St. Washoe Valley
 MAILING ADDRESS 293 Surrey Ct. Reno, NV 89521

2. LOCATION SE 1/4 SE 1/4 Sec. 31 T 17N N/S R 20E E Washoe County
 PERMIT NO. 050-406-11 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand brown		0	13	13
D.G. sand		13	36	23
D.G. sand brown clay streaks		36	64	28
Rusty D.G. some gravel		64	91	27
Gray sandy clays some boulders		91	109	18
Green sandy clay		109	164	55
Gray sandy clays		164	192	28
Gray granite		192	201	9
Fracture	x	201	207	6
Gray granite		207	220	13

Washoe County Well Permit # WL 060041

8. WELL CONSTRUCTION
 Depth Drilled 220 Feet Depth Cased 220 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 220 Feet
10 5/8 Inches
 _____ Inches
 _____ Inches

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+2</u>	<u>220</u>

Perforations:
 Type perforation Machine cut
 Size perforation 3/32 x 3
 From 80 feet to 100 feet
 From 140 feet to 160 feet
 From 200 feet to 220 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 56 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 56 feet to 220 feet

9. WATER LEVEL
 Static water level 52 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Bruce MacKay Pump & Well Service, Inc. Contractor
 Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
 Nevada contractor's license number issued by the State Contractor's Board 23096
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed R. Bruce MacKay
 By driller performing actual drilling on-site or contractor
 Date 3/22/2006

Date started 3/15/2006 .19
 Date completed 3/21/2006 .19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	
	G.P.M.	Time (Hours)
Draw Down (Feet Below Static)	<u>25</u>	<u>3</u>