WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99438
Permit No.
Basin 107

NOTICE OF INTENT NO. 56406

1. OWNER Robert Delpanto
MAILING ADDRESS P.O. Box 227 Hawthorne Nev. 89415
ADDRESS AT WELL LOCATION No. 1 Wilson Canyon Road

2. LOCATION S 1/2 ¼ SE ¼ Sec. 13 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. (Issued by Water Resources) 10-471-04 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil + gravel		0	2	2
brown clay + grave mix		2	8	6
gravel + sand		8	20	12
Clay brown		20	25	5
Clay grave mix		25	40	15
gray clay + grave mix	yes	40	80	40
gray clay	yes	80	140	60
gray clay + gravel	yes	140	160	20
fine gravel	yes	160	200	40

Date started March 25, 2006
Date completed March 29, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30+	10 ft.	3 hrs

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		188	0	200

Perforations:
Type perforation factory serv slott
Size perforation 1/16 x 3
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 60 ft
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 60 feet to 200 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Edmund Miller Drilling (Contractor)
Address P.O. Box 92 Smith Nev. 89430 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 32166A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718
Signed Edmund Miller (By driller performing actual drilling on site or contractor)
Date April 11-06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627