

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56409

1. OWNER Jamie Allen King ADDRESS AT WELL LOCATION 297 Washington St  
 MAILING ADDRESS P.O. Box 122 Yerington Nev 89447  
 2. LOCATION NE 1/4 3 E 1/4 Sec 11 T 12 N/S R. 25 E Lyon County  
 PERMIT NO. 012-25114 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>loose dry top soil</u>		<u>0</u>	<u>6</u>	<u>6</u>
<u>clay + gravel mud</u>		<u>6</u>	<u>12</u>	<u>6</u>
<u>gravel + cobbles</u>	<u>yes</u>	<u>12</u>	<u>40</u>	<u>28</u>
<u>Cobbles + gravel</u>	<u>yes</u>	<u>40</u>	<u>60</u>	<u>20</u>
<u>Cobbles + gravel</u>	<u>yes</u>	<u>60</u>	<u>70</u>	<u>10</u>
<u>clay + gravel mud</u>	<u>yes</u>	<u>70</u>	<u>100</u>	<u>30</u>
<u>gravel + clay</u>	<u>yes</u>	<u>100</u>	<u>140</u>	<u>40</u>
<u>gravel</u>	<u>yes</u>	<u>140</u>	<u>150</u>	<u>10</u>
<u>Coarse gravel</u>	<u>yes</u>	<u>150</u>	<u>220</u>	<u>70</u>

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>188</u>	<u>0</u>	<u>220</u>

Perforations:  
 Type perforation Hectory saw slott  
 Size perforation 3 3/32 x 3  
 From 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 220 feet

9. WATER LEVEL  
 Static water level 20 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

Date started April 4, 20 06  
 Date completed April 8, 20 06

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>40+</u>	<u>5</u>	<u>3 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Edmund Miller Drilling Contractor  
 Address P.O. Box 92 Contractor  
Smith Nev 89430  
 Nevada contractor's license number 32166 A  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718  
 Signed Edmund Miller  
 By driller performing actual drilling on site or contractor  
 Date April 11 - 06