

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27236

1. OWNER Steve McCrosky ADDRESS AT WELL LOCATION Junction of Hwy 93 and SR 319  
MAILING ADDRESS P.O. Box 208 Panaca NV 89042

2. LOCATION S/W 1/4, N/W 1/4 Sec 8 T 2 N 68 E Lincoln County

PERMIT NO. 12-170-56 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	10	10
Sandy clay		10	40	30
Clay-sand		40	50	10

Installed 1" steel tremmie pipe  
flushed 48" of silt out of well with  
fresh water used tremmie pipe to break  
or dislodge bottom cap pumped  
next cement from bottom up using  
approximately 20 gals. this is almost  
3 times more than casing holds

Location was approx 60' from Yellow  
Line of US 93 and 200' south of  
gas pumps

8. WELL CONSTRUCTION

Depth Drilled 50' Feet Depth Cased 50' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet
8	0	50	Feet
			Feet
			Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PCU	sch 40	0	50

Perforations:

Type perforation Factory slot

Size perforation .020

From 20 feet to 50 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 18'

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From 18' feet to 50 feet

9. WATER LEVEL

Static water level 30' feet below land surface

Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name DAVIS Drilling + Pumps Contractor

Address MC 61 Box 54 Contractor  
Hiko NV 89017

Nevada contractor's license number issued by the State Contractor's Board 0028966

Nevada driller's license number issued by the Division of Water Resources the on-site driller 1191

Signed Mark Jew  
 By driller performing actual drilling on site or contractor

Date 5-5-06

Date started 5-3-06, 20 \_\_\_\_\_

Date completed 5-4-06, 20 \_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

DCNR/DWR

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

MAY 5 2006

LAS VEGAS OFFICE