WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99447
Permit No.
Basin Ø87

NOTICE OF INTENT NO. 57395

1. OWNER Stanford Crossing LLC.
MAILING ADDRESS 2620 Island View Ln.
Lummi Island, WA 98262

ADDRESS AT WELL LOCATION 1544 S Stanford Way
Sparks NV.

2. LOCATION SW 1/4 SE 1/4 Sec. 9 T 19N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 034-145-05 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 6 5/8 X 29' well by perforating with Mills Knife from 29' to the surface at one foot intervals and four around. We then pumped neat cement mixed 5.2 gallons of water per sack. We pumped using tremie pipe from the bottom of the well to the top of the well.				
No Well Log Found				
Washoe Co. Permit # WL060058				

Date started 4/4/2006, 19__
Date completed 4/4/2006, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 29 Feet Depth Cased 29 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet
Inches	Feet	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	29

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 29 feet to 0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 2 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 4/4/2006

USE ADDITIONAL SHEETS IF NECESSARY