WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99468
Permit No. 26489, 26631, 27084
Basin 179

NOTICE OF INTENT NO. 558216

1. OWNER Ray E Moser
MAILING ADDRESS PO Box 1444
McGill, NV 89318

ADDRESS AT WELL LOCATION

2. LOCATION SW ¼ SE ¼ Sec. 30 T. 21 N/S R 64 E White Pine County

PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
Void ~~☒ Domestic~~ ☒ Irrigation Correct ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay Sand		0	20	
Clay		20	33	
Cobbles, Clay		33	47	
Sand, Clay		47	70	
Gravels, Clay		70	83	
Clay		83	106	
Sand Clay		106	197	
w Gravels				
Gravels, w Cobbles		197	262	
w Clay layer				
Cobbles		262	273	
Gravels		262	303	
w/Clay layers				

Date started 4/3/06, 20
Date complated 4/5/06, 20

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
800-1000		5 hrs

8. WELL CONSTRUCTION
Depth Drilled 300' Feet Depth Cased 300' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
25" Inches	1 Feet	300' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16"	42	.250	1	300

Perforations:
Type perforation Machine Perf
Size perforation 1/8 x 2½ x Triple Row Perf
From 60 feet to 300' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 60
Placement Method: ☒ Pumped ☐ Poured

Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 60 feet to 300' feet

9. WATER LEVEL
Static water level 4' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Peach Drilling Inc
Contractor
Address PO 599
Contractor
SS NV 89429

Nevada contractor's license number issued by the State Contractor's Board 0031841

~~Nevada driller's~~ license number ~~issued~~ by the Division of Water Resources, the on-site driller 1876

Signed [signature]
By driller performing actual drilling on site or contractor

Date 4/10/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627