REPORT NO. A06.031

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

LOG NO. 99473
PERMIT NO.
BASIN Ø89

NOTICE OF INTENT NO. 57943

1. OWNER Paul Sitze
MAILING ADDRESS 4220 Eastlake Blvd Carson City, NV 89704

ADDRESS OF WELL 4220 Eastlake Blvd
~~Carson~~ Washoe City, NV 89704

2. WELL LOCATION ~~SW~~ NW 1/4. NE 1/4 SEC. 5 T 16N R 20 E Washoe COUNTY
PERMIT NO PARCEL NO 50-431-06 SUBDIVISION NAME

3. TYPE OF WORK
[ ] New Well [ ] Replace [ ] Recondition
[X] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

| MATERIAL | STRATA | FROM | TO | THICKNESS |
|---|---|---|---|---|
| DG sands, large multicolor rock | | 116 | 160 | 44' |
| Firmer weathered granite with | | 160 | - | - |
| specs of gray clay | | 160 | 200 | 40' |
| Hard weathered granite | | 200 | 230 | 30' |

Notes: Latitude: N38 43.146' Longitude: W119 29.747'
Bottom 20' of bore hole full of large multicolor rock. Large multicolor rock would not clean out with drilling mud.

Date Started 4/6/06 Date Completed 4/14/06

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [X] Air Develop

| | GPM | DRAWDOWN | TIME (HRS) |
|---|---|---|---|
| | 20 | | 4 |
| | | | |
| | | | |

8. WELL CONSTRUCTION
Depth Drilled 230' Depth Cased 210'

HOLE DIAMETER (BIT SIZE)
6 1/8 Inches 116 Feet 230 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

| Size OD | Weight/Ft | Wall Thickness | From | To |
|---|---|---|---|---|
| 5" | 9.66 | .188 | 90' | 210' |
| | | | | |
| | | | | |
| | | | | |

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32" x 3"
From 130' Feet to 170' Feet
From Feet to Feet
From Feet to Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth
PLACEMENT METHOD: [ ] Pumped [ ] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [ ] Yes [ ] No
From Feet to Feet

9. WATER LEVEL
Static Water Level 67 Feet Below Land Surface
Artesian Flow GPM PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO. 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed Roger m. Thiel
By driller performing actual drilling on site or contractor

Dated April 14, 2006