COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99474
Permit No.
Basin 101

NOTICE OF INTENT NO. 57212

1. OWNER DAVID YOUNK
MAILING ADDRESS 4141 SCHINDLER
FALLON, NV 89406

ADDRESS AT WELL LOCATION 4141 SCHINDLER
FALLON, NV 89406

2. LOCATION NE ¼ NE ¼ Sec 16 T 18 N R 28 E CHURCHILL County

PERMIT NO. (Issued by Water Resources) | 006-471-01 (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	15	14
BROWN CLAY		15	19	4
BROWN SAND		19	28	9
BROWN CLAY		28	30	2
GRAY SANDS		30	60	30
BLACK SILTY CLAY		60	90	30
GRAY SANDS		90	130	40
GRAY CLAY		130	140	10
BROWN SAND	X	140	150	10

RECEIVED 2006 MAY -1 AM 1:24 STATE ENGINEER'S OFFICE

Date started APRIL 26, 20 06
Date completed APRIL 26, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION

Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	150 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	150

Perforations:
Type perforation MACHINE SLOT
Size perforation .088
From 144 feet to 148 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 20'4" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date APRIL 30, 2006

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com