COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99497
Permit No.
Basin 105

NOTICE OF INTENT NO. 56745

1. OWNER JASON DAEMEN
MAILING ADDRESS GARDNERVILLE , NV 89410
ADDRESS AT WELL LOCATION 2460 MT COMO
GARDNERVILLE , NV 89410

2. LOCATION ~~SW~~ ¼ ~~SE~~ ¼ Sec 4 T 12 N R 21 E DOUGLAS County
PERMIT NO. NE NW (Issued by Water Resources) | 1221-04-001-021 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| BROWN CLAY | | 0 | 4 | 4 |
| COURSE GRAVELS | | 4 | 35 | 31 |
| BROWN CLAY | | 35 | 162 | 127 |
| COURSE SANDS | | | | |
| BROWN CLAY | | 162 | 209 | 47 |
| FRACTURED GRAVELS | | | | |
| SMALL CLAY BALLS | XX | 209 | 250 | 41 |

Date started 4/12 , 20 06
Date completed 4/15 , 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25+ | 45 | 3 HRS |

8. WELL CONSTRUCTION

Depth Drilled 250' Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 3/4 Inches | 0 Feet | 250 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13.03 | .188 | +2 | 10 |
| 6 5/8sdr21 | 4.24 | 4.06 | 10 | 250 |

Perforations:
Type perforation SAW CUT
Size perforation 3X 3/32
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 100 ☐ Neat Cement
Placement Method: ☐ Pumped ☒ Cement Grout
☒ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 100 feet to 250 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M 25+ P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLING (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY , NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 4/21/06