WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99505
Permit No.
Basin 162

NOTICE OF INTENT NO. 29896

1. OWNER ENRICH SCHUERGER
MAILING ADDRESS 581 W HURACAN ST
PAHRUMP, NV

ADDRESS AT WELL LOCATION 581 W HURACAN ST

2. LOCATION SW 1/4 SE 1/4 Sec. 28 T 20S N/S R 53E E NYE County
PERMIT NO. Issued by Water Resources | 40-403-04 Parcel No. | CALVADA VALLEY UNIT 5 Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	31	31
CALICHE		31	46	15
CLAY		46	75	29
CALICHE	WB	75	82	7
CLAY		82	120	38
CALICHE	WB	120	135	15
CLAY		135	156	21
CALICHE	WB	156	180	24
CLAY		180	200	20
CALICHE	WB	200	223	23
CLAY		223	240	17

DCNR/DWR
RECEIVED
JUN 07 2006
LAS VEGAS OFFICE

Date started 6/1/2006 , 19__
Date completed 6/1/2006 , 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	240	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	.250	0	240

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X3
From 160 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 73 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
Address 1220 E MANSE RD Contractor
PAHRUMP, NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed By driller performing actual drilling on-site or contractor
Date 6/2/2006

USE ADDITIONAL SHEETS IF NECESSARY