


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
 WELL DRILLER'S REPORT

OFFICE USE ONLY  
 Log No. 99512  
 Permit No. 69701  
 Basin 230



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 29916

1. OWNER ASH MEADOWS, LLC ADDRESS AT WELL LOCATION ASH MEADOWS  
 MAILING ADDRESS ASH MEADOWS  
AMARGOSA, NV

2. LOCATION NE 1/4 NW 1/4 Sec. 25 T 18 N/S R 50 E NYE County  
 PERMIT NO. 69701 Parcel No. 21-351-13 Subdivision Name \_\_\_\_\_  
Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE Mining WELL TYPE  
 Domestic  Irrigation  Test  Cable  Rotary  RVC  
 Municipal/Industrial  Monitor  Stock  Air  Other \_\_\_\_\_

5. LITHOLOGIC LOG

| Material  | Water Strata | From | To  | Thickness |
|-----------|--------------|------|-----|-----------|
| CLAY      |              | 0    | 17  | 17        |
| GRAVEL    | WB           | 17   | 19  | 2         |
| CLAY      |              | 19   | 35  | 16        |
| LIMESTONE | WB           | 35   | 36  | 1         |
| CLAY      |              | 36   | 72  | 36        |
| GRAVEL    | WB           | 72   | 78  | 6         |
| CLAY      |              | 78   | 85  | 7         |
| CALICHE   | WB           | 85   | 87  | 2         |
| GREY ROCK | WB           | 87   | 300 | 213       |

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12.75 Inches To 0 Feet 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 8                  | .188                | 16.94                   | 0           | 300       |

Perforations:  
 Type perforation SAWCUT  
 Size perforation 1/8 X 3

|                         |                 |
|-------------------------|-----------------|
| From <u>100</u> feet to | <u>120</u> feet |
| From <u>140</u> feet to | <u>160</u> feet |
| From <u>180</u> feet to | <u>200</u> feet |
| From <u>220</u> feet to | <u>240</u> feet |
| From <u>260</u> feet to | <u>280</u> feet |

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 300 feet

9. WATER LEVEL  
 Static water level 4 FT feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor  
 Address 1220 E MANSE RD Contractor  
PAHRUMP, NV. 89048  
 Nevada contractor's license number issued by the State Contractor's Board 47333  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed [Signature] By driller performing actual drilling on-site or contractor  
 Date 5/19/2006

Date started 5/16/2006, 19  
 Date completed 5/19/2006, 19

7. WELL TEST DATA

| TEST METHOD:  | Draw Down (Feet Below Static) | Time (Hours) |
|---|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift |                               |              |
| G.P.M.  |                               |              |

DCNR/DWR  
 RECEIVED

JUN 02 2006

LAS VEGAS OFFICE