

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 52987

1. OWNER Tracy Boyer ADDRESS AT WELL LOCATION 355 Rowell Cir. 14700 Red Rock Rd  
 MAILING ADDRESS 355 Rowell Cir. Reno NV 89506  
 Reno NV 89506  
 2. LOCATION NW 1/4 NE 1/4 Sec. 23 T. 23 S. R. 18 E. Washoe County  
 PERMIT NO. NE NW 078-122-05 Parcel No. Sierra Rancho Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To  | Thick-ness |
|----------|--------------|------|-----|------------|
| Sand     | Br           | 0    | 15  | 15         |
| Clay     | Bl.          | 15   | 20  | 5          |
| Sand     | Bl.          | 20   | 176 | 156        |
| Clay     | Bl.          | 176  | 179 | 3          |
| Sand     | Br.          | 179  | 220 | 41         |

GPS  
 N 39. 84888  
 W 119. 93318

8. WELL CONSTRUCTION  
 Depth Drilled 220 Feet Depth Cased 220 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches 0 Feet 220 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6 5/8</u>       | <u>12.9</u>         | <u>.188</u>             | <u>2+</u>   | <u>220</u> |

Perforations:  
 Type perforation Saw Slot  
 Size perforation 3/16"  
 From 180 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 220 feet

9. WATER LEVEL  
 Static water level 10 feet below land surface  
 Artesian flow No G.P.M. NA P.S.I.  
 Water temperature NA °F Quality NA

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Olenki Drilling & Pump Co. Contractor  
 Address 15045 Red Rock Rd Contractor  
Reno NV 89506  
 Nevada contractor's license number issued by the State Contractor's Board 50343  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656  
 Signed John J. Olenki  
 By driller performing actual drilling on site or contractor  
 Date 5/1/06

Date started 4/27 2006  
 Date completed 4/29 2006

7. WELL TEST DATA

| TEST METHOD:  | G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|---|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift | <u>60</u> | <u>200</u>                    | <u>3</u>     |