

Lot # 8

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENT'S COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

OFFICE USE ONLY  
Log No. 99541  
Permit No. \_\_\_\_\_  
Basin 101

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 54284  
ADDRESS AT WELL LOCATION 1835 Heidi Fallon

1. OWNER Don Gerhart / Fkb Builders  
MAILING ADDRESS \_\_\_\_\_  
2. LOCATION NE 1/4 NW 1/4 Sec 20 T 19 N/S R 28 E Churchill County  
PERMIT NO. 008-175-05 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other MLL

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & CLAY		0	35	
SAND		35	60	
Gravle		60	80	
CLAY		80	105	
SAND		105	140	

8. WELL CONSTRUCTION  
Depth Drilled 140 Feet Depth Cased 140 Feet  
HOLE DIAMETER (BIT SIZE)  
From 10 7/8 Inches To 0 Feet 140 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>		<u>188</u>	<u>72</u>	<u>20</u>
<del>6 7/8</del>		<del>507-21</del>	<del>77</del>	<del>140</del>
<u>6 5/8</u>		<u>SPR 21</u>	<u>20</u>	<u>140</u>

Perforations:  
Type perforation SKILL SWP  
Size perforation \_\_\_\_\_  
From 110 feet to 140 feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
Depth of Seal 60  Neat Cement  
Placement Method:  Pumped  Concrete Grout  
 Poured  
Gravel Packed:  Yes  No  
From 140 feet to 60 feet

9. WATER LEVEL  
Static water level 35 ft feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature 60.1 °F Quality \_\_\_\_\_

Date started 1-24, 2006  
Date completed 1-24, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>60</u>	<u>26</u>	<u>3</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge.  
Name Boach Drilling Inc Contractor  
Address P.O. Box 399 Contractor  
Silver Springs NV  
Nevada contractor's license number 0031891 issued by the State Contractor's Board  
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2225  
Signed F. Syler NW  
By driller performing actual drilling on site or contractor  
Date 1-25-06