

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56872

1. OWNER Gryphon Gold ADDRESS AT WELL LOCATION HATHORNE NEVADA  
 MAILING ADDRESS 390 Union Blvd. Suite 360 BOREALIS MINE  
Lakewood Colorado 80228  
 2. LOCATION NW 1/4 NW 1/4 Sec 17 T 6 N/S R 29 E MINERAL County  
 PERMIT NO. WPCD NEV 2005101 MW: 1780 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Clay Rich Alluvium</u> <u>40%</u>		<u>0'</u>	<u>185'</u>	<u>185'</u>
<u>Volcanic Bedrock</u>		<u>185'</u>	<u>240'</u>	<u>55'</u>
<u>10-100# Sand</u>		<u>240'</u>	<u>194.5'</u>	<u>46.5'</u>
<u>3-50# 3/8 Bentonite chip</u>		<u>194.5'</u>	<u>193.5'</u>	<u>1'</u>
<u>9-50# Superfines</u>		<u>193.5'</u>	<u>8'</u>	<u>185.5'</u>
<u>6-94# Portland Type II</u>		<u>8'-0'</u>	<u>8'</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 240' Feet Depth Cased 237.5' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
6 7/8" Inches 0' Feet 240' Feet  
10" Inches 0' Feet 20' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2"</u>	<u>Sch. 80</u>		<u>197.5'</u>	<u>+2 1/2'</u>
<u>6 5/8"</u>		<u>.157</u>	<u>0'</u>	<u>+3'</u>

Perforations:  
 Type perforation Horizontal-Factory  
 Size perforation .020  
 From 197.5' feet to 237.5' feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 20'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 240' feet to 194.5' feet

9. WATER LEVEL  
 Static water level 201.5' feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature Cold °F Quality CLEAN

Date started 2-9, 2006  
 Date completed 2-10, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>TRALE</u>			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eklund Drilling Contractor  
 Address P.O. Box 2748 Contractor  
Elko, NEVADA 89803  
 Nevada contractor's license number issued by the State Contractor's Board 0030823  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller M-1820  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 2-10-06