COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99571
Permit No.
Basin 212

NOTICE OF INTENT NO. 29780

1. OWNER WYNN LAS VEGAS LLC
MAILING ADDRESS 3131 LAS VEGAS BLVD. S
LAS VEGAS, NV 89109

ADDRESS AT WELL LOCATION 3141 S. LAS VEGAS BLVD.
LAS VEGAS, NV

2. LOCATION SE ¼ SW ¼ Sec 09 T 21 S R 61 E CLARK County

PERMIT NO. DW1218 (Issued by Water Resources) | 162-09-410-001 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Dewater

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
21-Dewater wells				
Asphalt & type II		0	2	2'
Silt		2	6	4
Brown alluvium & rock		6	13	7
Tan alluvium & rock		13	16	3
White alluvium & rock		16	19	3
Caliche		19	25	6
Caliche	xx	25	35	10
Brown clay		35	43	8
Red clay		43	54	11
Tan clay		54	60	6

DCNR/DWR
RECEIVED
MAY 26 2006
LAS VEGAS OFFICE

Date started 4/25, 20 06
Date completed 5/5, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
24"	Inches	0 Feet	60 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Machine
Size perforation
From 30 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Gravel Packed: ☒ Yes ☐ No
From 0 feet to 60 feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☐ Concrete Grout

9. WATER LEVEL
Static water level 25 feet below land surface
Artesian flow no G.P.M P.S.I
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC (CONTRACTOR)
Address 4015 West Tompkins Ave. (CONTRACTOR)
Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed Fred R. Allen III
By driller performing actual drilling on site or contractor
Date May 23, 2006

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com