


COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340



PRINT OR TYPE ONLY

1. OWNER **3700 ASSOCIATES LLC**
 MAILING ADDRESS **667 MADISON AVE**
NEW YORK, NY 10021-8029

ADDRESS AT WELL LOCATION **3698 S. LAS VEGAS BLVD.**
LAS VEGAS, NV

NOTICE OF INTENT NO. **30041**

2. LOCATION **SW 1/4 NE 1/4 Sec 20 T 21 S R 61 E** **CLARK** County
 PERMIT NO. **DW1220** **162-20-603-007**

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other **Dewater**

4. PROPOSED USE **Dewater**
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
1-Dewatering wells				
Asphalt		0'	3"	3"
Brown dirt		3"	8'	7'-9"
Caliche		8'	14'	6'
Brown silt	XX	14'	17'	3'
Brown silty clay		17'	21'	4'
White clay		21'	26'	6'
Red clay		26'	28'	2'
Brown clay		28'	35'	6'
White silty clay		35'	48'	7'
Brown clay & small rock		48'	51'	9'
Caliche		51'	55'	3'
Red clay		55'	63'	3'
White clay		63'	85'	6'

8. WELL CONSTRUCTION

Depth Drilled **85** Feet Depth Cased **85** Feet

HOLE DIAMETER (BIT SIZE)
 From **24"** Inches To **0** Feet **85** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation **Machine**
 Size perforation **.25" x 2.5 x 3 rows @ 13**
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Depth of Seal _____ Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From **0** feet to **85** feet

Date started **5/22, 20 06**
 Date completed **5/22, 20 06**

7. WELL TEST DATE

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL

Static water level _____ **12** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **ALLEN DRILLING INC.** (CONTRACTOR)
 Address **4015 WEST TOMPKINS AVE.** (CONTRACTOR)
LAS VEGAS, NV 89103
 Nevada contractor's license number issued by the State Contractor's Board **18916 & 18917**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2231**
 Signed *Vito Allen*
 By driller performing actual drilling on site or contractor
 Date **5/31/06**