COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99602
Permit No.
Basin 101

NOTICE OF INTENT NO. 56671

1. OWNER CHARLIE MORROW
MAILING ADDRESS 145 SUTRO ROAD
FALLON, NV 89406

ADDRESS AT WELL LOCATION 2194 LONGHORN
FALLON, NV 89406

2. LOCATION SE ¼ SE ¼ Sec 12 T 18 N R 28 E CHURCHILL County

PERMIT NO. (Issued by Water Resources) | 006-351-39 (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN SAND		1	10	9
BROWN CLAY		10	15	5
BROWN SAND		15	30	15
GRAY CLAY		30	33	3
GRAY SANDS		33	70	37
BLACK SILT		70	80	10
GRAY SANDS		80	95	15
GRAY CLAY		95	97	2
BROWN SANDS	X	97	108	11

RECEIVED 2006 APR 11 AM 11:48 STATE ENGINEER'S OFFICE

Date started JANUARY 29, 20 06
Date completed MARCH 15, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1HR

8. WELL CONSTRUCTION

Depth Drilled 108 Feet Depth Cased 108 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	108 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	108

Perforations:
Type perforation MACHINE SLIT
Size perforation .088
From 102 feet to 106 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Gravel Packed: ☐ Yes ☒ No
From feet to feet

Seal Type:
☐ Neat Cement
☐ Cement Grout
☒ Concrete Grout

9. WATER LEVEL
Static water level 19'7" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date 4/9/06

Forms Provided by Forms-On-A-Disk, Inc. · (214) 340-9429 · FormsOnADisk.com