

**STATE OF NEVADA
DIVISION OF WATER RESOURCES**

OFFICE USE ONLY

Log No. 99636
Permit No. _____
Basin 10

**PRINT OR TYPE ONLY
DO NOT WRITE ON BACK**

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56622

1. OWNER Dwight Turner
MAILING ADDRESS 4240 Horseshoe Dr. Fallon, NV 89406
Fallon, NV 89406

ADDRESS AT WELL LOCATION 4240 Horseshoe
Fallon, NV 89406

2. LOCATION ^{SW} ~~NW~~ 1/4 NW 1/4 Sec. 16 T 18N R 28E
PERMIT NO. Parcel No. 006-171-49

Subdivision Name Churchill County
Lot

3. WORK PERFORMED
New Well

4. PROPOSED USE
Domestic

5. WELL TYPE
Rotary-mud

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|------------|--------------|------|-----|------------|
| Brown Sand | | 0 | 10 | 10 |
| Brown Clay | | 10 | 18 | 8 |
| Brown Sand | | 18 | 24 | 6 |
| Gray Clay | | 24 | 36 | 12 |
| Gray Sand | | 36 | 46 | 10 |
| Black Clay | | 46 | 58 | 12 |
| Black Sand | | 58 | 74 | 16 |
| Black Clay | | 74 | 82 | 8 |
| Brown Clay | | 82 | 94 | 12 |
| Brown Sand | | 94 | 98 | 4 |
| Gray Clay | | 98 | 110 | 12 |
| Gray Sand | | 110 | 123 | 13 |
| Black Clay | | 123 | 133 | 10 |
| Black Sand | | 133 | 146 | 13 |
| Brown Clay | | 146 | 152 | 6 |
| Brown Sand | X | 152 | 158 | 6 |

8. WELL CONSTRUCTION

Depth Drilled 158 Depth Cased 158 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|-----------|---------|----------|
| 12 Inches | 0 Feet | 50 Feet |
| 10 Inches | 50 Feet | 158 Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (inches) | Weight/Ft. (Pounds) | Wall Thickness | From (Feet) | To (Feet) |
|--------------------|---------------------|----------------|-------------|-----------|
| 6.625 | 12.92 | 6.625 | 0 | 20 |
| 6 | 3.82 | 0.258 | 20 | 158 |

Perforations:

Type perforation Saw Cut
Size perforation 0.0625
From 153 feet to 158 feet

Surface Seal: Yes No

Seal Type:

Depth of Seal 50

Concrete Grout

Placement Method: Pumped

Gravel Packed: Yes No

From 50 feet to 158 Feet

9. WATER LEVEL

Static Water Level 18 feet below land surface

Artesian Flow G.P.M. P.S.I.

Water temperature ° F Quality unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contractor

Address 403 McLean Road

Fallon, NV 89407

Contractor

Nevada contractor's license number 29064
issued by the State Contractor's Board

Nevada driller's license number issued by the 2307
Division of Water Resources, the on-site driller

Signed [Signature]

By driller performing the actual drilling on site or contractor

Date 2/9/2006

Date started 1/27/2006

Date completed 1/27/2006

7. WELL TEST DATA

TEST METHOD

| Comments | GPM | Drawdown | Time (Hours) |
|----------|-----|----------|--------------|
| | | | |
| | | | |
| | | | |

Latitude

Longitude