WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99640
Permit No.
Basin 105

NOTICE OF INTENT NO. 54214

1. OWNER MR JOHANSON
MAILING ADDRESS GARDNERVILLE, NV
ADDRESS AT WELL LOCATION 1780 WATSON CT. GARDNERVILLE, NV

2. LOCATION SE ¼ SE ¼ Sec. 26 T. 13 (N) S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 1320-26-002-041 (Parcel No.) STAR VIEW RIDGE (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY W/GRAVEL		0	9	9
SANDY CLAY		9	16	7
SANDY CLAY W/GRAVEL		16	21	5
CLAY		21	27	6
SANDY CLAY W/GRAVEL		27	83	56
GRAVEL W/SAND	✓	83	121	38
SANDY CLAY W/GRAVEL		121	296	175
SAND	✓	296	302	6
SANDY CLAY		302	307	5
SAND	✓	307	310	3
SANDY CLAY		310	314	4
SAND	✓	314	316	2
SANDY CLAY		316	318	2
SAND	✓	318	320	2

UTM E 0266375
N 4315216
NAD 27

RECEIVED 2006 MAR -1 PM 3:45 STATE ENGINEERS OFFICE

Date started 1/18, 2006
Date completed 2/2, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	20+	—	4

8. WELL CONSTRUCTION
Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
9 7/8 Inches		50 Feet	320 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	+1	320

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 X 3/32
From 100 feet to 120 feet
From 300 feet to 320 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 320 feet

9. WATER LEVEL
Static water level 160 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DESERT DRILLING CORPORATION (Contractor)
Address 811 SPRING VALLEY DR. (Contractor)
GARDNERVILLE, NV 89410
Nevada contractor's license number issued by the State Contractor's Board 60503
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2282
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 2/23/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627