WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99646
Permit No.
Basin 179

NOTICE OF INTENT NO. 55262

1. OWNER Ron Jenkins
MAILING ADDRESS P.O. Box 150602
Ely, NV 89315

ADDRESS AT WELL LOCATION Cross Timbers

2. LOCATION N1/2 1/4 SESE 1/4 Sec. 15 T 17 N/S R 63 E White Pine County
PERMIT NO. Issued by Water Resources
Parcel No. 005-571-66
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Light Tan Clay		0	115	115
Sand & Gravel	X	115	123	8
Clay		123	125	2
Sand & Gravel	X	125	127	2
Cemented Gravel		127	167	40
Clay		167	171	4
Fractured Rock	X	171	174	3
Clay		174	180	6

Date started 2-28-06, 19__
Date completed 2-28-06, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Approx	85		2.5

8. WELL CONSTRUCTION
Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	180	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	188	+1	20
6	SDR-17		20	180

Perforations:
Type perforation Screen
Size perforation .050
From 160 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 51
Placement Method: [X] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Bentonite 20-51
Gravel Packed: [X] Yes [ ] No
From 51 feet to 180 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sharel C. Fertig Sr. DBA Fertig Drill. (Contractor)
Address P.O. Box 525 (Contractor)
Elko, NV 89803
Nevada contractor's license number issued by the State Contractor's Board 31904
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584
Signed (By driller performing actual drilling on-site or contractor)
Date 3-29-06

USE ADDITIONAL SHEETS IF NECESSARY