

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 99653
Permit No. _____
Basin 10

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please fill in this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56969

1. OWNE Dwayne South
MAILING ADDRESS P.o. Box Reno, NV 89510
Reno, NV 89510

ADDRESS AT WELL LOCATION 740 Joel Way
Fallon, NV 89406

2. LOCATION NE 1/4 NE 1/4 Sec 6 T 18 R 29
PERMIT NO SW Parcel No. 006-691-68

Latitude 39.45378 Longitude -118.7686 WGS 84
Subdivision Name _____ County Churchill

3. WORK PERFORMED
New Well

4. PROPOSED USE
Domestic

5. WELL TYPE
Rotary-mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	8	8
Brown Clay		8	14	6
Brown Sand		14	30	16
Black Clay		30	36	6
Black Sand		36	92	56
Brown Clay		92	96	4
Brown Sand	X	96	106	10

8. WELL CONSTRUCTION

Depth Drilled 106 Depth Cased 106 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12.3 Inches	0 Feet	50 Feet
10 Inches	50 Feet	106 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (inches)	Weight/Ft. (Pounds)	Wall Thickness	From (Feet)	To (Feet)
6.625	12.92	6.625	0	20
6	3.85	0.258	20	106

Perforations:

Type perforation Saw Cut
Size perforation 0.0625
From 101 feet to 106 feet

Surface Sea Yes No

Seal Type:

Depth of Seal 50

Concrete Grout

Placement Method: Pumped

Gravel Packed: Yes No

From 50 feet to 106 Feet

9. WATER LEVEL

Static Water Level 10 feet below land surfac

Artesian Flow G.P.M. P.S.I.

Water temperature ° F Qualit unknown

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Parsons Drilling, Inc.

Contracto

Address 403 McLean Road

Fallon, NV 89407

Contracto

Nevada contractor's license number 29064
issued by the State Contractor's

Nevada driller's license number issued by the 2307
Division of Water Resources, the on-site driller

Signe [Signature]

By driller performing the actual drilling on site or contract

Date 3/29/2006

Date started 3/22/2006

Date completed 3/22/2006

7. WELL TEST DATA

TEST METHOD

Comments	GPM	Drawdown	Time (Hours)