

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56042

1. OWNER Scott Marris ADDRESS AT WELL LOCATION 145 W. Morning Glory Lane
 MAILING ADDRESS 1801 Shaner Lane
LV NV 89156

2. LOCATION SW 1/4 SE 1/4 Sec. 12 T. 12 N/S R. 61 E. White Pine County
 PERMIT NO. N/A 12-025-03 Preston town site
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	1	
clay gravel cobbles		1	12	
clay		12	16	
gravel clay		16	31	
CLAY		31	37	
clay gravel		37	40	
gravel clay		40	50	
Clay gravel conglomerate		50	68	
gravel conglomerate	water	68	81	
Clay gravel		81	89	
CLAY		89	94	
gravel	water	94	97	
Clay con		97	106	
gravel	water	106	108	
CLAY		108	114	
gravel	water	114	118	
CLAY		118	127	
gravel	water	127	131	
CLAY		131	150	
gravel	water	150	155	
Clay con		155	165	
gravel	water	165	167	
CLAY con		167	180	

8. WELL CONSTRUCTION
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 50 Feet
8 Inches 50 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>12.9</u>	<u>.188</u>	<u>0</u>	<u>20</u>
<u>6</u>		<u>5/16 40 PVL</u>	<u>20</u>	<u>180</u>

Perforations:
 Type perforation mill
 Size perforation 1032 x 6 rows

From _____ feet to _____ feet
 From 100 feet to 120 feet
 From _____ feet to _____ feet
 From 140 feet to 180 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 180 feet

9. WATER LEVEL
 Static water level 72 feet below land surface
 Artesian flow _____ G.P.M. P.S.I.
 Water temperature 60 °F Quality good

Date started March 23 2006
 Date completed April 13 2006

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>1</u>	<u>1hr</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Maynard Well Drilling Contractor
 Address P.O. Box 64 Lund NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 47224
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1554

Signed David Maynard
 By driller performing actual drilling on site or contractor
 Date April 28 -06