

WHITE-DIVISION OF WATER RESOURCES  
 CANARY-CLIENT'S COPY  
 PINK-WELL DRILLER'S COPY  
 Hole Well #  
 PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK



STATE OF NEVADA  
 DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY

Log No. 99676  
 Permit No. 76789, 76789, 768537, 768557  
 Basin. 149

NOTICE OF INTENT NO. 25526

1. OWNER Rich Hale Potato Patch ADDRESS AT WELL LOCATION  
 MAILING ADDRESS Vern Fredrickson Stone Cabin  
 SW RC 6-12-06 p. 4 Fax on 2-7-06  
 2. LOCATION NE 1/4 SE 1/4 Sec. 11 T 1 R 46 E Nye County  
 PERMIT NO. 31594-60139 65021 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		1	25	
Coarse Sand		25	46	
Cobbles & gravel		46	122	
(Some clay layers)				
Gravel Cobbles		122	180	
Boulders Cobbles		180	117	
Clay Sand		117	265	
Clay Sand layers		265	337	
Cobbles Boulders		337	402	
Clay		402	407	
Coarse Cobbles		407	450	

N 37.95185  
 W 116.79099 NAD27  
 24 FT 4-9-06 RC

8. WELL CONSTRUCTION  
 Depth Drilled 450 Feet Depth Cased 450 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 22 1/2 Inches To 4 3/4 Feet  
 Casing Schedule  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
110	72	.230	1	450

 Perforations: Johnson Well Screen, 50  
 Type perforation Machine Pump  
 Size perforation Triple Row 3 1/2 x 3  
 From 200 feet to 350 M.P. feet  
 From 350 feet to 450 U.W.S. feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
 Depth of Seal 50  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 450 feet

9. WATER LEVEL  
 Static water level 122 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature C °F Quality Good

Date started 01/13/06, 20  
 Date completed 01/12/06, 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>500</u>		<u>1.5 hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Reach Drilling Inc Contractor  
 Address PO 899 Contractor  
Silver Spring NV 89429  
 Nevada contractor's license number 0031841  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 01/13/06