WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99707
Permit No.
Basin 091

NOTICE OF INTENT NO. 57083

1. OWNER Truckee Meadows Water
MAILING ADDRESS P.O. Box 30013 Reno Nv. 89520
ADDRESS AT WELL LOCATION Near Mouth of Highland ditch Verdi Nv.

2. LOCATION NE ¼ NE ¼ Sec. 16 T. 19 N/S R. 18 E. Washoe County
PERMIT NO. W-585A Issued by Water Resources
APN 038-430-11 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Big Cobbles		0	16	16
Clay / Sand & Gravel		16	20	4
Fine Sand	22	20	22	2
Silt / Siltstone (grey)		22	35	13
Grey Clay		35	105	70
Brown Siltstone / clay		105	111	6
Silt/clay (grey)		111	153	42
Weathered Siltstone & Clay		153	185	32
Silt/clay (Brown)		185	195	10
Clay (light grey)		195	239	44
Clay (Dark Brown)		299	258	19
Clay (Black		258	264	6
Silt/clay (Brown)		264	269	5
Silt/clay (Black)		269	273	4
Clay (Brown) Siltston(grey)		273	285	12
Clay (Blue)		285	292	7
Siltstone (grey)		292	332	40
Silt/clay (Dark Brown)		332	360	28
Silt/clay (grey)		360	375	15
Silt/clay (Dark Brown)		375	395	20
Silt/clay (Black)		395	400	5
Silt/clay (grey)		400	430	30
Silt/Clay (Brown)		430	475	45
Siltstone (grey)				
Neat Cement		0	475	475

Date started March 20, 20 06
Date completed March 24, 20 06

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 475 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8½" Inches	0 Feet	475 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		N/A		

Perforations:
Type perforation N/A
Size perforation
From feet to feet
From N/A feet to N/A feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 475'
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 22' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WOC Exploration & Wells Contractor
Address 9580 County RD. 93 B Contractor
Zamora CA 95698
Nevada contractor's license number issued by the State Contractor's Board 0012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2263
Signed By driller performing actual drilling on site or contractor
Date 03/31/06

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627