

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56886

1. OWNER Round Mountain Gold Corp. ADDRESS AT WELL LOCATION #1 Mine Rd. Round Mountain, NV 89045  
 MAILING ADDRESS P.O. Box 480 Round Mountain, NV 89045

2. LOCATION SE 1/4 SW 1/4 Sec. 14 T 10 R 43 E Nye County  
 PERMIT NO. NEV91030 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. MW 110 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Alluvium sand small amount of clay and gravel boulders</u>		<u>160</u>	<u>0</u>	<u>160</u>
<u>#8 Sand 81/50# bags</u>		<u>160</u>	<u>160</u>	<u>60'</u>
<u>3/8" bentonite chips 52/50# bags</u>		<u>100</u>	<u>20</u>	<u>80</u>
<u>Nevada Type II cement 8/99# bags</u>		<u>20</u>	<u>0</u>	<u>20</u>

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 158 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>14 3/4</u>	<u>0</u>	<u>79</u>		
<u>8 3/4</u>	<u>19</u>	<u>160</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10 3/4"</u>		<u>1/4"</u>	<u>+1</u>	<u>19</u>
<u>4 1/2"</u>		<u>1/4" PVC</u>	<u>+2</u>	<u>158</u>

Perforations:  
 Type perforation Horizon +1 slot  
 Size perforation .020

From 118 feet to 158 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From Blank +2 feet to 118 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 20'  Neat Cement  
 Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 100 feet to 160 feet

9. WATER LEVEL  
 Static water level 113 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality clean

Date started 5/8 2006  
 Date completed 5/16 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>10</u>		
<u>AT TD</u>			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Jason Poole Contractor Eklund Drilling Inc  
 Address P.O. Box 2748 Eiko, NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 0030823  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 169871  
 Signed Jason Poole By driller performing actual drilling on site or contractor  
 Date 5/16/06