

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 57015

1. OWNER Newmont mining Corp ADDRESS AT WELL LOCATION Twin Creeks mine - Hyd Dept
 MAILING ADDRESS Newmont mining Corp Hyd Dept. P.O. Box 69 Gilconda NV, 89414 North of Gilconda, NV
 2. LOCATION NE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 18 T. 39 N S. R. 43 E. Humboldt County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. m/018-15B LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Oxide and Limestone</u>		<u>from 0 to 1360</u>		
<u>Sulfide + Carbon (black) mix</u>		<u>with more Limestone to 1360</u>		
		<u>to 1800 TD</u>		
<u>Set 2 3/8 (2 1/16 nominal)</u>		<u>from -1797 to +3'</u>		
<u>Trimmy in 1/4 gravel from</u>		<u>1800 to 1450 (2 1/2 Super SKS)</u>		
<u>place 3/8 hole plug from</u>		<u>1450 to 50' - (280 SKS 50lb)</u>		
<u>Pour in Cement 150 gal</u>		<u>(12 SKS 94lb)</u>		
<u>Develop well with Air through</u>		<u>Trimmy - then inject 100 gal</u>		
<u>Water for every joint of</u>		<u>Screen in each joint on way</u>		
<u>out - stop at each Screen Pump</u>		<u>100 gal Pull Back 20' Pump 100</u>		
<u>gal etc for all 15 joints</u>				
<u>weld monument on</u>				

8. WELL CONSTRUCTION
 Depth Drilled 1800 Feet Depth Cased 1797 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 1620
6 1/4 Inches 0 Feet 1620 Feet
6 1/4 Inches 1620 Feet 1800 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2 3/8</u>	<u>3.65</u>	<u>1/8</u>	<u>+3</u>	<u>1797</u>

Perforations:
 Type perforation Slot
 Size perforation 1/8
 From 1757 feet to 1457 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50' Cement Grout
 Placement Method: Pumped Poured Concrete Grout
 Gravel Packed: Yes No
 From 1800 feet to 1450 feet

9. WATER LEVEL
 Static water level 1058 feet below land surface
 Artesian flow NO G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality Dirty - Carbon

Date started 5/19, 2006
 Date completed 6/5, 2006

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>		

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Eklund Drilling Co Contractor
 Address P.O. Box 2748 Contractor
Eiko, NV 89803
 Nevada contractor's license number 0030823
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 2089
 Division of Water Resources, the on-site driller
 Signed D. S. L.
 By driller performing actual drilling on site or contractor
 Date 6/5/06