

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56596

1. OWNER Jeff Prejean
MAILING ADDRESS P.O. Box 20936
Reno, NV 89515

ADDRESS AT WELL LOCATION Hwy 50 & Spring Flower

2. LOCATION NE 1/4 NE 1/4 Sec. 21 T 19N
PERMIT NO. 007-021-02
Issued by Water Resources Parcel No. Subdivision Name

N/S R 26E E Chuchill County

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hard tan silt		0	80	80
Hard silt some sand		80	140	60
Broken volcanic rock sand silt		140	180	40
Black broken volcanic rock		180	240	60
Broken volcanic rock silt		240	300	60
Hard tan silt		300	440	140
Red volcanic rock fractured	x	440	505	65

8. WELL CONSTRUCTION
Depth Drilled 505 Feet Depth Cased 505 Feet

HOLE DIAMETER (BIT SIZE)

	From	To	
10 5/8 Inches	0	378	Feet
6 1/8 Inches	378	505	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	378
5	10.79	.188	365	505

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 258 feet to 298 feet
From 445 feet to 505 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout
Gravel Packed: Yes No
From 50 feet to 378 feet

9. WATER LEVEL
Static water level 380 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started 1/25/2006 .19
Date completed 2/7/2006 .19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift		
G.P.M. <u>30</u>		<u>3</u>

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 2/10/2006