WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99804
Permit No.
Basin 087

NOTICE OF INTENT NO. 57383

1. OWNER Charles Hilton
MAILING ADDRESS 1100 Zolezzi Ln.
Reno, NV 89511

ADDRESS AT WELL LOCATION 1120 Zolezzi Ln.

2. LOCATION NW 1/4 NW 1/4 Sec. 20 T 18N N/S R 20E E Washoe County
PERMIT NO. (Issued by Water Resources) | Parcel No. 049-351-34 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
On this date we abandoned a 8" X 104' well that was deepened to 219' and a 6" liner installed from 80' to 219'. Then in 1996, because of sand, a 5" liner was installed from 2' to 200' and gravel packed. Perfs in the 6" were from 180-200'. We perforated from 180' to 54' with Mills Knife. We then pumped 4 cubic yards of neat cement mixed 5.2 gallons of water per sack using tremie pipe from the bottom to the top of the well. Casing was in a vault and top of casing was about 8' from ground level.				
Washoe County Permit # WL060029				

Date started 2/15/2006, 19__
Date completed 2/15/2006, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 219 Feet Depth Cased 219 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	104
6 5/8	12.92	.188	80	219
5	10.79	.188	2	200

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 54 feet to 180 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 104 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2271
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 2/15/2006

USE ADDITIONAL SHEETS IF NECESSARY