WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99806
Permit No.
Basin 107

NOTICE OF INTENT NO. 56609

1. OWNER Dan McClure
MAILING ADDRESS 263 Artesia Rd.
Wellingtn, NV 89444

ADDRESS AT WELL LOCATION 263 Artesia Rd.
Wellingtn

2. LOCATION NW 1/4 NW 1/4 Sec. 28 T 12N N/S R 23E E Lyon County
PERMIT NO. Issued by Water Resources
9-011-21 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
DG boulders		0	40	40
DG boulders small				
gravel		40	100	60
DG boulders brown clay		100	120	20
DG large boulders		120	160	40
Boulders small gravels				
DG sand	x	160	220	60
Boulders brown clay		220	230	10

Date started 2/17/2006, 19__
Date completed 2/24/2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
100		3

8. WELL CONSTRUCTION
Depth Drilled 230 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
12 1/4	Inches	0	Feet	230	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	230

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 150 feet to 210 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 230 feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 3/1/2006

USE ADDITIONAL SHEETS IF NECESSARY