WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99829
Permit No.
Basin 107

NOTICE OF INTENT NO. 54291

1. OWNER Right Way Investment Co.
MAILING ADDRESS Reno, NV

ADDRESS AT WELL LOCATION Smith Valley (Wright Way Farms)

2. LOCATION SE ¼ SW ¼ Sec. 26 T. 13 N N/S R. 23 E. Lyon County
PERMIT NO. Ap No. ~~72979~~ 72980 W-584 Smith Valley
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Gravels		1	26	
Clay		26	72	
Gravels		72	78	
Clay		78	160	
(Gravel w/Clay layers)		160	193	
Clay		193	210	
Gravels		210	218	
Clay		218	243	
Gravels		243	260	
Clay		260	270	
(Gravels/Clays layers)		270	315	
Gravels		315	370	
Clay		370	390	
(Gravels/Clay layers)		390	510	
Gravels		510	550	
Clay		550	570	
Gravels		570	590	
Clay w/Gravels layers		590	600'	

Date started 2/7/06, 20
Date complated 2/18/06, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☒ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
approx	3500+	Air lift	8½
	5000+	Test pump	
	Carson Pumps		
	105' FT. DRAW DOWN.		

8. WELL CONSTRUCTION
Depth Drilled 600' Feet Depth Cased 600' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
22½ Inches	1 Feet	600' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16.	42	.250	1	600'

Perforations:
Type perforation Machine Perf
Size perforation 1/8 x 2½ x Tripple Row Perf
From 200' feet to 600' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured

Seal Type:
☐ Neat Cement
☒ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 600' feet

9. WATER LEVEL
Static water level 1+ feet below land surface
Artesian flow estimated 250 G.P.M. P.S.I.
Water temperature 82 °F Quality Acceptable

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc
Contractor
Address P.O. Box 589
Contractor
S.S. NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876
Signed [signature]
By driller performing actual drilling on site or contractor
Date 3/3/06

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627