WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99833
Permit No.
Basin Ø88

NOTICE OF INTENT NO. 56615

1. OWNER Greg McIntosh
MAILING ADDRESS 5425 Tannerwood
Reno, NV 89511

ADDRESS AT WELL LOCATION 5425 Tannerwood Reno

2. LOCATION NW 1/4 NE 1/4 Sec. 2 T 17N N/S R 19E E Washoe County
PERMIT NO. Dom05-048 Issued by Water Resources | 045-541-21 Parcel No. | Subdivision Name

3. **WORK PERFORMED**
☐ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. **PROPOSED USE**
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. **WELL TYPE**
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
Rock sand gravels		0	160	160
Rock sand	x	160	280	120
Rock sand little clay		280	300	20
Sand cobbles boulders	x	300	500	200

Washoe County Well Permit # WL 050324

Date started 12/27/2005 , 19__
Date completed 12/29/2005 , 19__

7. **WELL TEST DATA**

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
50+		3

8. **WELL CONSTRUCTION**
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	500	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	500

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3

From 240 feet to 260 feet
From 300 feet to 320 feet
From 360 feet to 380 feet
From 480 feet to 500 feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 500 feet

9. **WATER LEVEL**
Static water level 175 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Coo °F Quality Not tested

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. Contractor
Address 1600 Mt. Rose Hwy Contractor
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay
By driller performing actual drilling on-site or contractor
Date 1/10/2006

USE ADDITIONAL SHEETS IF NECESSARY