

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY

Log No. 99839
 Permit No. _____
 Basin Ø71

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 55638

PRINT OR TYPE ONLY

1. OWNER David and Becky Unger
 MAILING ADDRESS 320 S. Ham Lane
Lodi, CA 95240
 ADDRESS AT WELL LOCATION 10245 S Grass Valley Road
Winnemucca, NV 89445

2. LOCATION E 1/2 1/4 lot 10 1/4 Sec 36 T 35 N R 37 E Humboldt County
 PERMIT NO. 014-377-04
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------|--------------|------|-----|------------|
| Topsoil | | 0 | 3 | 3 |
| Sand & gravel | | 3 | 60 | 57 |
| Clay | | 60 | 80 | 20 |
| Gravel | | 80 | 87 | 7 |
| Clay | | 87 | 95 | 8 |
| Gravel | | 95 | 105 | 10 |
| Clay | | 105 | 130 | 25 |
| Sand & gravel | X | 130 | 155 | 25 |
| Clay | | 155 | 160 | |

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 6 5/8 | 10 | 188 | +1 | 20 |
| 6.625 | 4.06 | .316 | 20 | 160 |

Perforations:
 Type perforation Factory cut
 Size perforation 0.50
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Good

Date started February 20, 20 06
 Date completed February 22, 20 06

7. WELL TEST DATE

| TEST METHOD: | <input type="checkbox"/> Bailer | <input type="checkbox"/> Pump | <input checked="" type="checkbox"/> Air Lift |
|--------------|---------------------------------|-------------------------------|--|
| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) | |
| <u>20</u> | | <u>4</u> | |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Fred Anderson & Sons Drilling, Inc.
 (CONTRACTOR)
 Address 10760 Grass Valley Road
 (CONTRACTOR)
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 021467
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
 Signed _____
 By driller performing actual drilling on site or contractor
 Date March 8, 2006