COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99841
Permit No.
Basin 107

NOTICE OF INTENT NO. 54336

1. OWNER ROB STINNETTE CONSTRUCTION
MAILING ADDRESS P.O. BOX 11
WELLINGTON, NV 89444

ADDRESS AT WELL LOCATION 56 HAWK VIEW DR
SMITH VALLEY NV 89444

2. LOCATION ~~SW~~ ¼ ~~SW~~ ¼ Sec 12 T 11 N R 23 E LYON County

PERMIT NO. NW SE (Issued by Water Resources) | 009-132-12 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVEERBURDEN		0	4	4
DROWN DG SANDS		4	36	32
BROWN SANDS		36	110	74
BROWN CLAY		110	172	62
GRAY CLAY		172	205	33
SMALL GRAVELS INBEDED IN GRAY CLAY SOFT AREA	XXX	205	250	45

Date started 1/8, 20 06
Date completed 1/9, 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	60	3 HRS

8. WELL CONSTRUCTION

Depth Drilled 250' Feet Depth Cased 250' Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	250'	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	+2	10
6 5/8sdr21	4.06	.216	10	250

Perforations:
Type perforation SAW CUT
Size perforation 3X3/32
From 210 feet to 250 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 250 feet

Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M 35 P.S.I
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CAPITAL CITY WELL DRILLIG (CONTRACTOR)
Address 20 KIT KAT DRIVE (CONTRACTOR)
CARSON CITY, NV 89706
Nevada contractor's license number issued by the State Contractor's Board 0055548
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Rick Crane
By driller performing actual drilling on site or contractor
Date 1/15/06