WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99849
Permit No.
Basin 042

NOTICE OF INTENT NO. 56491

1. OWNER CHAD BURKEY
MAILING ADDRESS HC64 BOX 5
DEETH, NV 89813

ADDRESS AT WELL LOCATION BAR HL ROAD

2. LOCATION NE 1/4 NW 1/4 Sec. 17 T 38N N/S R 63E E ELKO County
PERMIT NO. _____ Issued by Water Resources
008-570-010 Parcel No.
BAR HL Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL W/ROCKS		0	5	
SAND, GRAVEL W/ROCKS		5	10	5
COARSE SAND AND GRAVEL		10	100	90
GRAVEL W/SOME CLAY		100	180	80
GRAVEL W/SOME CLAY	180	180	210	30
SANDSTONE W/SOME CLAY		210	220	10

Date started 1/17/2006, 19__
Date completed 1/20/2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
7.5		2

8. WELL CONSTRUCTION
Depth Drilled 220 Feet Depth Cased 220 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	220 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	12.92	.188	+1	220

Perforations:
Type perforation SLOTTED
Size perforation 3/16X3 6 ROWS
From 180 feet to 200 feet
From 200 feet to 220 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet 220 feet

9. WATER LEVEL
Static water level 95 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name HACKWORTH DRILLING, INC. Contractor
Address P. O. BOX 850 Contractor
ELKO, NV 89803

Nevada contractor's license number issued by the State Contractor's Board 020582

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1166

Signed Dale C. Vedder
By driller performing actual drilling on-site or contractor

Date 1/25/2006