REPORT NO. A06.005

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

LOG NO. 99899
PERMIT NO.
BASIN Ø52A

NOTICE OF INTENT NO. 57099

1. OWNER Byron Wholey
MAILING ADDRESS P.O. Box 60412 Reno, NV 89506

ADDRESS OF WELL 10160 Crockett Dr.
Reno, NV 89506

2. WELL LOCATION SE 1/4 ~~NW~~ NE 1/4 SEC. 25 T 21N R 18E E Washoe COUNTY

PERMIT NO ____ PARCEL NO 86-171-19 SUBDIVISION NAME ____

3. TYPE OF WORK
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Plug [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Mud

6. LITHOLOGIC LOG

MATERIAL	STRATA	FROM	TO	THICKNESS
Sands, brown clay & DG		0	5	5
Tan clays, silty gray clay, DG		5	20	15
Sands, silty gray clay, firm DG		20	35	15
Light green clay, DG		35	70	35
Green/blue gray clay/some DG		70	90	20
Green clay		90	110	20
DG, less clay		110	130	20
DG, sandy greenish gray clay		130	150	20
Coarse sands, no clay	X	150	170	20
Hard blue green clay		170	192	22
Coarse sands, firm DG	X	192	239	47

Notes: Aqua drilled 58' at Lat: N39 39.479, Long: W119 54.460; filled in borehole w/ native material to 15' & concrete grout to surface; moved drill to: Lat: N39 39.480, Long: W119 54.475 & drilled new well.

Date Started 1/23/06 Date Completed 1/25/06

7. WELL TEST DATA

TEST METHOD [ ] Bailer [ ] Pump [ ] Air Develop

	GPM	DRAWDOWN	TIME (HRS)
	20+		2 hours

8. WELL CONSTRUCTION

Depth Drilled 239 Depth Cased 239

HOLE DIAMETER (BIT SIZE)
10 Inches 0 Feet 239 Feet
____ Inches ____ Feet ____ Feet
____ Inches ____ Feet ____ Feet

CASING SCHEDULE

Size OD	Weight/Ft	Wall Thickness	From	To
6 5/8	12.92	.188	+1	239

PERFORATIONS:
Type Perforation Factory Size Perforation 3/32 x 32
From 179 Feet to 219 Feet
From ____ Feet to ____ Feet
From ____ Feet to ____ Feet

SURFACE SEAL: [X] Yes [ ] No
Seal Depth 50
PLACEMENT METHOD: [ ] Pumped [X] Poured

SEAL TYPE:
[ ] Neat Cement
[ ] Cement Grout
[X] Concrete Grout
[ ] Bentonite

GRAVEL PACKED: [X] Yes [ ] No
From 50 Feet to 239 Feet

9. WATER LEVEL
Static Water Level 50 Feet Below Land Surface
Artesian Flow ____ GPM ____ PSI
Water Temperature cool F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of m knowledge.

Name Aqua Drilling & Well Service, Inc.
Address 675 Edison Way
Reno, NV 89502

NV. CONTRACTOR'S LIC. NO 15291 DRILLER'S LIC. NO. ON SITE 2189

Signed [signature]
By driller performing actual drilling on site or contractor

Dated January 25, 2006