

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK



WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 56916

1. OWNER Bordenman Casino ADDRESS AT WELL LOCATION 19555 Hwy 395 North Cold Springs, NV 89506
 MAILING ADDRESS 19575 Hwy 395 North Cold Springs, NV, 89506
 2. LOCATION NE 1/4 SE 1/4 Sec 19 T 21 R 18 E Churchill County
 PERMIT NO. Facility Id # 4-060204 (Apr) 840-140-16 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other HSA

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|---------------------------------|--------------|------------|------------|----------------|
| <u>Asphalt</u> | | <u>0</u> | <u>6"</u> | <u>6"</u> |
| <u>Sand - grey brown</u> | | <u>6"</u> | <u>18'</u> | <u>17 1/2'</u> |
| <u>Clayey sand - grey brown</u> | | <u>18'</u> | <u>28'</u> | <u>10'</u> |
| <u>Clay - brown</u> | | <u>28'</u> | <u>38'</u> | <u>10'</u> |
| <u>Clay + sand - brown</u> | | <u>38'</u> | <u>48'</u> | <u>10'</u> |
| <u>Clay - brown</u> | | <u>48'</u> | <u>60'</u> | <u>12'</u> |

8. WELL CONSTRUCTION
 Depth Drilled 60' Feet Depth Cased 60' Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10.25" Inches 0 Feet 60' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>4"</u> | | <u>9SCH 40</u> | <u>0</u> | <u>60'</u> |

 Perforations:
 Type perforation factory slot
 Size perforation .020
 From 40 feet to 60 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 38' Neat Cement
 Placement Method: Pumped 5' barite seal 33'-38' Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 38' feet to 60' feet

9. WATER LEVEL
 Static water level 45 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 65 °F Quality _____

Date started Mar 23, 2006
 Date completed Mar 23, 2006

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|------------|-------------------------------|--------------|
| <u>1.5</u> | <u>6'</u> | <u>1/2</u> |

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Haz Tech Drilling Contractor
 Address P.O. 940 Madia Id 83660 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0038018
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2312
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 4-26-06