WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99924
Permit No.
Basin 103

NOTICE OF INTENT NO. 56588

1. OWNER Oakwood Homes
MAILING ADDRESS 9825 B S. Virginia St.
Reno, NV 89511

ADDRESS AT WELL LOCATION 6400 Wild Horse Run
Stagecoach 6560

2. LOCATION NW 1/4 SE 1/4 Sec. 7 T 17N N/S R 23E E Lyon County
PERMIT NO. (Issued by Water Resources) 015-323-36 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulders silt		0	80	80
Hard volcanic rock		80	100	20
Hard volcanic rock tan		100	300	200
Gray tan volcanic rock		300	360	60
Fractured volcanic rock	X	360	480	120

Date started 4/24/2006, 19__
Date completed 4/27/2006, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		3

8. WELL CONSTRUCTION
Depth Drilled 480 Feet Depth Cased 480 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	118	Feet
6 1/8	Inches	118	Feet	480	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+2	118
5	10.79	.188	100	480

Perforations:
Type perforation Machine cut
Size perforation 3/32 x 3
From 420 feet to 480 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 118 feet

9. WATER LEVEL
Static water level 195 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Not tested

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1790
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 5/2/2006

USE ADDITIONAL SHEETS IF NECESSARY