



STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 99931
 Permit No. _____
 Basin 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 51407

1. OWNER Chuck & Mary Burnham ADDRESS AT WELL LOCATION 2231 N. 21st West Street, Ely, Nevada 89301
 MAILING ADDRESS 2231 N. 21st West Street Ely, Nevada 89301

2. LOCATION SW 1/4 SE 1/4 Sec 22 T 17 N R 63 E White Pine County
 PERMIT NO. _____ APN 05-591-49 Cross Timbers Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	3	3
Sand & Course Gravel		3	20	17
Sand & Gravel		20	40	20
Clay		40	45	5
Sand & Gravel		45	55	10
Clay & Gravel		55	70	15
Water Bearing Sand & Gravel	X	70		
			85	15
Clay & Gravel		85	100	15
Brown Clay		100	137	37
Water, Sand & Gravel	X	137	150	13
Brown Clay		150	162	12

8. WELL CONSTRUCTION
 Depth Drilled 162 Feet Depth Cased 162 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 162 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	162

Perforations:
 Type perforation Factory
 Size perforation 1 7/8" X 2 1/2" 6 Rows
 From 82 feet to 162 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Feet Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 162 feet

9. WATER LEVEL
 Static water level 64 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started April 3 2005
 Date completed April 14 2005

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
45	96	4	

Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada 89301

Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793

Signed Rich Lewis By Gerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date May 9, 2006