COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99933
Permit No.
Basin 101

NOTICE OF INTENT NO. 56663

1. OWNER CSE CONSTRUCTION
MAILING ADDRESS 1791 POTPOURRI
FALLON, NV 89406

ADDRESS AT WELL LOCATION 1791 POTPOURRI
FALLON, NV 89406

2. LOCATION SE ¼ NW ¼ Sec 22 T 19 N R 28 E CHURCHILL County

PERMIT NO. (Issued by Water Resources) | 008-221-10 (Parcel No.) | (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP SOIL		0	1	1
BROWN CLAY		1	14	13
BROWN SAND		14	25	11
BROWN CLAY		25	30	5
GRAY CLAY		30	36	6
GRAY SAND/CLAY		36	70	34
BROWN SAND		70	81	11
GRAY SILT		81	100	19
GRAY SANDS		100	130	30
GRAY CLAY		130	140	10
GRAY SANDS		140	155	15
BROWN CLAY		155	159	4
BROWN SANDS	X	159	173	14

Date started MAY 3, 20 2006
Date completed MAY 4, 20 2006

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1 HR

8. WELL CONSTRUCTION

Depth Drilled 173 Feet Depth Cased 173 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 3/4 Inches	0 Feet	50 Feet
6 Inches	50 Feet	173 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	~~130~~ 173

Perforations:
Type perforation MACHINE SLOT
Size perforation .080
From 164 feet to 168 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 50 ☐ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 20'8" feet below land surface
Artesian flow G.P.M P.S.I
Water temperature COOL °F Quality UNTESTED

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WELSCO CORP. (CONTRACTOR)
Address P. O. BOX 888 (CONTRACTOR)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2199
Signed
By driller performing actual drilling on site or contractor
Date MAY 17, 2006