WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99945
Permit No.
Basin 162

NOTICE OF INTENT NO. 29958

1. OWNER Utilities Inc. of Centarl Nevada
MAILING ADDRESS 5551 N. Leslie
Pahrump, NV 89060

ADDRESS AT WELL LOCATION
~~551~~ N. Leslie
5551

2. LOCATION N/E 1/4 N/E 1/4 Sec. 17 T 19S N/S R 53E E Nye County
PERMIT NO. Issued by Water Resources
31-381-01 Parcel No.
Calvada North Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
brown silty loam		0	19	19
brown clay		19	25	6
brown clay with pea gravel		25	31	6
brown loam		31	42	11
See next line		42	72	30
brown clay with caleche strings				
brown loam	x	72	132	60
brown loam with pea gravel	x	132	133	1
brown loam	x	133	140	2

DCNR/DWR
RECEIVED
JUN 29 2006
LAS VEGAS OFFICE

Date started 6/15/1906 2006, 19__
Date completed 6/15/1906, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 135 Feet Depth Cased 125+1 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches	0 Feet	140 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 1/2	.69	.154	0	115

Perforations:
Type perforation Factory Perf
Size perforation 0.020
From 90 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 78 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Strickland Construction Co., Inc. Contractor
Address 5801 S. Homestead Contractor
Pahrump, NV 89048
Nevada contractor's license number issued by the State Contractor's Board 40277
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2086
Signed [signature] By driller performing actual drilling on-site or contractor
Date 6-27-06