COPIES TO
- DIVISION OF WATER RESOURCES
- CLIENT'S COPY
- WELL DRILLER'S COPY

PRINT OR TYPE ONLY

STATE OF NEVADA

DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99963
Permit No.
Basin 071

NOTICE OF INTENT NO. 55639

1. OWNER Roberta Rothwell
MAILING ADDRESS 38349 17th Street East
Palmdale, CA 93550

ADDRESS AT WELL LOCATION 9460 Sabin Road
Winnemucca, NV 89445

2. LOCATION Lot 3 ¼ NE 1/2 ¼ Sec 30 T 35 N R 38 E Humboldt County

PERMIT NO. | Issued by Water Resources | 10-646-03 Parcel No. | Tycana Subdivision Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0	2	2
Course Gravel		2	42	40
Cobles and Gravel		42	90	48
Clay		90	105	15
Cobles and Gravel		105	120	15
Clay		120	130	10
Boulders		130	155	25
Clay & Cobles		155	265	110
Boulders		265	275	10
Clay & Rock		275	205	30
Cobles and Sand		305	340	35
Sand & Course Gravel	x	340	375	35
Clay		375	380	5
N 40,52, 835				
W 117 , 44, 377				
Elevation 4566				

Date started April 17 , 20 06
Date completed May 1 , 20 06

7. WELL TEST DATE

TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
13		12

8. WELL CONSTRUCTION

Depth Drilled 380 Feet Depth Cased 380 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	20 Feet
11 Inches	20 Feet	380 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10	188	+1	20
6.625	4.06	.316	20	380

Perforations:
Type perforation Factory cut
Size perforation 0.50
From 340 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No Seal Type:
Depth of Seal 55' ☒ Neat Cement
Placement Method: ☒ Pumped ☐ Cement Grout
☐ Poured ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 55 feet to 380 feet

9. WATER LEVEL
Static water level 275 feet below land surface
Artesian flow N/A G.P.M N/A P.S.I
Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred Anderson & Sons Drilling, Inc. (CONTRACTOR)
Address 10760 Grass Valley Road (CONTRACTOR)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 021467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2083
Signed
By driller performing actual drilling on site or contractor
Date May 15, 2006