0096086

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

3 wells

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 99996
Permit No.
Basin 212

Flamingo Sandhill LLC

NOTICE OF INTENT NO. 28871

1. OWNER Ron Branka
MAILING ADDRESS 145 S. State College Blvd
Brea CA

ADDRESS AT WELL LOCATION 3805 E. Flamingo Rd
Las Vegas NV

2. LOCATION NW ¼ NE ¼ Sec. 19 T. 21 N/S R. 62 E. Clark County

PERMIT NO. Issued by Water Resources | 161-19-521-001 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0.0	0.4	0.4
Type II Fill		0.4	6.0	5.6
Sandy Clay w/gravel & boulders		6.0	14.0	8.0
Sandy Clay w/gravel		14.0	19.0	5.0
Silty Clay w/gravel		19.0	30.0	11.0
Caliche		30.0	31.0	1.0
Clay w/sand		31.0	35.0	4.0

DCNR/DWR
RECEIVED
JUN 30 2006
LAS VEGAS OFFICE

Date started 6/27, 2006
Date completed 6/29, 2006

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35.0 Feet Depth Cased 35.0 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11½	Inches	0.0 Feet	35.0 Feet
	Inches	Feet	Feet
	Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.25		SCH 40 PVC	0.0	35.0

Perforations:
Type perforation Machine Slot
Size perforation .020
From 35.0 feet to 10.0 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 11'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 35.0 feet to 8.0 feet

9. WATER LEVEL
Static water level 14' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services LLC (Contractor)
Address 7150 Placid St (Contractor)
Las Vegas Nv. 89119
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-2272
Signed (By driller performing actual drilling on site or contractor)
Date 6/29/06

(Rev. 17-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627