

# WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA



Log No. 3492  
 Rec. July 20 1956  
 Well No. ....  
 Permit No. ....

*Do not fill in*

Owner Wm. C. Sandord Driller Bob Meyer  
 Address 43 North Street Reno, Nevada Address 306 Bath St. Carson City Lic. No. 209  
 Location of well: NW 1/4 SE 1/4 Sec. 10, T. 13 N/S, R. 19 E, in Douglas County  
 or Genoa, Nevada  
 Water will be used for Domestic Total depth of well 194 feet  
 Size of drilled hole 8 Inch Weight of casing per linear foot 19 lbs.  
 Thickness of casing 3/16 Inch Temp. of water Cool  
 Diameter and length of casing 8" ID, 194 feet  
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)  
 If flowing well give flow in c.f.s. or g.p.m. and pressure Not Flowing  
 If nonflowing well give depth of standing water from surface 90 feet  
 If flowing well describe control works Not Flowing  
(Type and size of valve, etc.)  
 Date of commencement of well June 20, 1956 Date of completion of well ~~XXXX~~ July 17, 1956  
 Type of well rig 71 Speed Star Cable Tools

### LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	24	24	Broken Rock & Caly
24	28	4	Hard Rock
28	34	6	Hard Rock & Caly
34	37	3	Hard Rock
37	67	30	Rock & Caly
67	76	9	Hard Rock & Clay
76	106	30	Hard Rock
106	130	24	Hard Rock & Clay
130	165	35	Rock & Clay
165	194	29	Hard Rock & Caly

Water-bearing Formation, Casing Perforations, Etc.

---

Chief aquifer (water-bearing formation)  
 from 100 ft to 193 ft.

Other aquifers.....  
 None

---

First water at 97 feet.

Casing perforated  
 from 100 to 193 ft.

Size of perforations  
1/8" X 6"



LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8", ID	0	194	194'	Standard Hard Rock Drive Shoe ( Clayton-Mards )

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Capacity Test With 1/4 Inch Turbon Set @ 190 feet ( Pump Rater 260 gal per Min. )

Well Will Make 60 gal Per min. @ 190 feet .

Total Pumping Time 30 hours

2 Biological Test Made by State Health Dept.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed.....

Well Driller

By..... Bob Meyer

License No..... 209

Dated..... July 17 ....., 19 56

(Not to be filled in by Driller)

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

OFFICE  
STATE ENGINEER

1956 JUL 20 AM 9 54