WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 3916
Rec. Nov. 4 1957
Well No.
Permit No.
Do not fill in

3-101-01

Owner RAYMOND CLYMER Driller JESSE J. HARRISON
HARRISON LANE
Address CARSON CITY Address HOT SPRINGS Rd CARSON CITY Lic. No. 6

Location of well: CCBB SW ¼ SW ¼ Sec. 3, T. 15 N/S, R. 20 E, in ORMSBY County

or N. END OF HARRISON LANE, HOT SPRINGS Rd ABOUT 1250' N. SEC LOR'S, Running Line #3 3-4-9-10

Water will be used for DOMESTIC PURPOSES Total depth of well 68' 6"

Size of drilled hole 16" Weight of casing per linear foot 10.088 lbs

Thickness of casing 1/4" Temp. of water COLD

Diameter and length of casing
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 24'

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well 7-22-57 Date of completion of well 7-24-57

Type of well rig ROTARY.

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	5	5	HARD PAN
5	9	4	SAND
9	35	26	clay
35	43	8	Gravel
43	60	17	clay
60	63	3	sand & gravel
63	64	1	Hard pan
64	65	1	sand & gravel
65	66	1	Hard pan
66	68½	2½	sand & gravel
68½	70	1½	Rock

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 66 to 68½ ft.

Other aquifers 64' to 65'
60' to 63'
all three the same

First water at ..... feet.

Casing perforated

from 60 to 68½ ft.

Size of perforations

3/16 x 6" on 3 sides of casing 6" apart.

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
4	0	68½	68½	4" black Iron Threads + Collars 1/4" thick weighs 10.088 lb. per ft. From 60 to 68½' is ~~[illegible]~~ 3 small strata with water that just below here are all the one aquifer. as I have 2 wells below here that the water is from 60 to 68 ft.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Not pumped.
Bailed 250 gals per hr 2 ft draw down
Good quality water

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Jesse J. Harrison
Well Driller

By

License No. 6

Dated Nov. OFFICE, 1957
STATE ENGINEER

1957 NOV 4 AM 10 07

(Not to be filled in by Driller)