WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

1

Log No. 4392
Rec. 2-6-59 10-59
Well No.
Permit No.
Do not fill in

Owner: Bonny M. Whitman
Driller: Harvey & Bob Meyer
Address: 207 Georgia St. Carson City
Address: 306 Bath St. Carson
Lic. No. 10

Location of well: ~~NW~~ SW ¼ ~~SW~~ NE ¼ Sec. ~~29~~ 26, T. ~~15~~ 16 N/S, R. ~~16~~ 19 E, in Washoe County

or List Ranch, Washoe Valley

Water will be used for: Domestic
Total depth of well: 190 feet

Size of drilled hole: 8 Inch
Weight of casing per linear foot: 19.64 #

Thickness of casing: 7/32" Or .219
Temp. of water: Cool

Diameter and length of casing: 8" ID, 163 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure: Not Flowing

If nonflowing well give depth of standing water from surface: 22 feet

If flowing well describe control works: Not Flowing
(Type and size of valve, etc.)

Date of commencement of well: January 19, 1959
Date of completion of well: February 4, 1959

Type of well rig: 71-B Speed Star, Cable Tool

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	5	5	Top Soil
5	15	10	Sand
15	19	4	Clay
19	30	11	Sand
30	40	~~XXX~~ 10	Gravel
40	81	41	Sand
81	120	39	Gravel
120	163	43	Sand
163	180	17	Sand Stone
180	190	10	Course Gravel

HARVEY & BOB MEYER
DRILLING CONTRACTORS
CARSON CITY, NEVADA

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 180 to 190 ft.

Other aquifers
80 to 120
30 to 40

First water at 12 feet.

Casing perforated
from 80 to 120 ft.
30 to 40

Size of perforations
1/4" X 1 1/2"
Mills

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8" ID	0	163	163	Standard Star Drive Shoe

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Well was tested at 40 feet made 3 G P M

Well was tested at 120 feet made 4.5 G P M

Well was tested at 190 feet, made 20 G P M from 40 feet.

(Bailer Test)

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Bob Meyer
Well Driller

By Bob Meyer

License No. 10 & 209

Dated February 4, 19 59

HARVEY & BOB MEYER
DRILLING CONTRACTORS
CARSON CITY, NEVADA

(Not to be filled in by Driller)

1959 FEB 9 AM 9 38

OFFICE
E ENGINEER