WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

I

Log No. 7163
Rec. May 14 1963
Well No.
Permit No. 21274
Do not fill in

Owner Jack Oxborrow Driller Gus Orsolini

Address P.O. Box 329 Zephyr Cove Nev. Address P.O. Box 862 Tahoe Valley Lic. No. 327

Location of well: NE¼ SW¼ Sec. 24, T. 13 N/S, R. 18 E, in Douglas County
1 8/10 mile from Hwy 50 on Kingsbury Highway 1

or 60 feet east of road on Kingsbury Highlands Properties

Water will be used for Domestic Total depth of well 198 ft.

Size of drilled hole 14" from 0' to 50' Weight of casing per linear foot

Thickness of casing 8 gauge Temp. of water cold

Diameter and length of casing 10" 88 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure none

If nonflowing well give depth of standing water from surface 23 feet

If flowing well describe control works none
(Type and size of valve, etc.)

Date of commencement of well 5-17-61 Date of completion of well 6-5-61

Type of well rig cable rig

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	5	5	soil
5	14	9	loose Decomposed Granite
14	28	14	gray D. G.
28	42	14	brown D. G.
42	71	29	gray D. G.
71	74	3	brown D. G.
74	88	14	gray D. G.
88	104	16	brown D. G.
104	109	5	gray D. G.
109	162	53	brown D. G.
162	167	5	Rock
167	191	24	brown D. G.
191	198	7	Rock

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 28 to 42 ft.

Other aquifers 71 to 74
88 to 104
109 to 162
167 to 191

First water at 28 to 42 feet.

Casing perforated

from 60 to 88 ft.

Size of perforations

1/8" x 5"

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
16"	0'	16'	16'	Conductor
10"	0'	88'	88'	Sealed with cement from 0 to 50 feet

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

30 hr. test with installed pump
40 G.P.M. with a 42 ft. drawdown
Time test was not made
quality of water clear and cold

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Gus Crosland
Well Driller

By Gus Crosland

License No. 327

Dated 6-19, 1961

(Not to be filled in by Driller)

1963 MAY 14 PM 3 31

STATE ENGINEER
OFFICE