LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6" ID	0'	105'	106½'	* Casing placed in 7½" open hole in 20' lengths with heavy threaded collars. *--Casing extends above ground level 1½'.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Well was test pumped by means of 4-inch turbine pump at 60-foot setting. Well surged and back flushed for period of 2-hours, at end of which time a closely measured gallonage test was applied. Result of test showed a measured 18-gallons a minute with measured drawdown of 31', Somewhat disappointing in view of the good formation encountered between 28-feet and 54-feet in the hole.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed GROSCH IRRIG. CO.
Well Driller

By [signature]
President Agent

License No.

Dated June 4, 19 63

(Not to be filled in by Driller)

1963 JUN 17 AM 9 54

STATE ENGINEER
OFFICE